

Each year BECQ-DEQ publishes its Underground Storage Tank Public Record, as required by the Energy Act Policy of 2005.

Title XV, Subtitle B of this act, contains amendments to Subtitle 1 of the Solid Waste Disposal Act - the original legislation that created the underground storage tank (UST) program. The amendments focus on preventing releases. Among other things, they expand eligible uses of the Leaking Underground Storage Tank (LUST) Trust Fund and include provisions regarding inspections, operator training, delivery prohibition, secondary containment and financial responsibility, and cleanup of releases that contain oxygenated fuel additives.

## CNMI UST/LUST PUBLIC RECORD AS OF December 30, 2016

**Public Record Posted Date:** December 30, 2016

<b>Total UST Facilities: 46</b> Total ACTIVE Facilities: <b>26*</b> Total INACTIVE Facilities: <b>7</b> Total CLOSED Facilities: <b>13</b>	<b>Total UST's: 136</b> Total ACTIVE Underground Tanks: <b>53</b> Total INACTIVE Underground Tanks: <b>11</b> Total CLOSED Underground Tanks: <b>75</b>
---	--

### COMPLIANCE.

<b>Inspection Period Dates:</b>	October 01, 2015 – September 30, 2016
<b>Number of Facilities Inspected:</b>	<b>28</b>
<b>Percent Compliance:</b>	<b>64%</b>
<b>Compliance Measured and Reported UST Universe Statements:</b>	Facility compliance is measured through field inspections for both release detection and release prevention (OUST Measure UST-6).  This means that of the 28 Facilities inspected during the inspection period, 64% are in compliance with EPA or CNMI UST regulations, which include release detection, and release prevention compliance. Ten (10) facilities received a Notice of Violation or Administrative Order in FY 2016.

### RELEASE.

<b>Release Reporting Period Dates:</b>	October 01, 2015 – September 30, 2016
<b>Number of Confirmed Releases:</b>	None.
<b>Percent of Releases by Source:</b>	None.
<b>Cause of Release:</b>	None.

For site specific information contact Reina Camacho at 670-664-8500

\* Facilities are inspected annually in the CNMI (EPA requires UST facilities inspected at least once every three years).

^ 19 Service Stations; 6 Private Firms; 1 Government.